

# Mariner 110 Fire Extinguisher

Part number 466627N

Multipurpose use

Disposable

## UL Rated 1-A, 10-B:C



## Description

Suitable for use on Class A (trash, wood & paper), Class B (liquids & gases) and Class C fires (energized electrical equipment).

The Mariner 110 unit is fitted with a pressure gauge that provides at-a-glance status, is manufactured from lightweight aluminum and a tough nylon valve assembly.



Includes plastic strap bracket (322057)

## At a Glance

- Model Mariner 110
- Multipurpose Dry Chemical
- UL listed
- UL rated 1-A, 10-B:C
- U.S.C.G, DOT approved
- Supplied with retention strap bracket
- Monoammonium Phosphate
- 6 year limited warranty
- Suitable for use on most common fires

For use on the following types of fire:



## Features

- Easy-to-read gauge tells you fire extinguisher is charged and ready for use
- Clear instruction label using graphics to show steps required to operate extinguisher
- Easy-to-pull safety pin
- Rust and impact resistant nylon handle
- 2.5 lb. of fire extinguishing agent (Average)
- 6 year limited warranty
- UL approved strap retention bracket
- Coast Guard (U.S.C.G) approved when fitted with supplied mounting bracket
- Powder coated cylinder for corrosion protection



Pt # 466627N- 6 pack  
 UPC: 0-47871-00627-4  
 IZF: 10047871006271

## Product Specification

Net agent weight (Average)	2.5 lb.
Unit weight (Average)	3.9 lb.
Diameter	3.25 inches
Height	14.3 inches
Discharge time	8-12 seconds
Discharge range	6-8 feet
Operating pressure	100 psi
Cylinder	Seamless aluminum
Valve, handle, lever	Nylon
Strap Bracket	U.S.C.G approved

## Packaging Options



Packaging dimensions (inches)

	Depth	Width	Height
Carton	3.25	4.25	14.1
Master Pack	9.1	14.75	10.0

# How To Use Your Kidde Extinguisher

Follow instructions shown on the front label of your fire extinguisher.

After the fire is out, clean up dry chemical powder immediately to avoid corrosion.


**CAUTION:** Under certain fire and heat conditions, the dry chemical powder in ABC type extinguishers will cause damage or prove extremely difficult to remove from oven surfaces, including self-cleaning models. Do not use self-cleaning feature to remove ABC Powder. BC type extinguishers are recommended for cooking areas.

**CAUTION:** The agent contained in this extinguisher is not toxic, but may cause skin irritation. Avoid inhaling the dry chemical agent. In case of contact, flush affected area with clean, cool water. If irritation persists, contact a physician immediately. Chemical name of agent is printed on extinguisher label. For more information on fire fighting, contact your local fire department or the U.S. Coast Guard. Additional information on extinguishers can be found in the National Fire Protection Association (NFPA) pamphlet No. 10, "Portable Fire Extinguishers."


## Mounting Your Extinguisher

Please follow the instructions and diagrams below for mounting the bracket that was supplied with your fire extinguisher.


U.S. Coast Guard approval is valid only with the marine mounting bracket specified on the instruction label of your extinguisher.



Metal strap bracket



Plastic wall hanger



Metal wall hanger

# Cómo Usar Su Extinguidor Kidde

Siga las instrucciones en la etiqueta del frente de su extinguidor.

Una vez que el fuego ha sido extinguido, limpie el polvo residual inmediatamente para evitar corrosión.

**ATENCIÓN:** Ante ciertas condiciones de temperatura, el polvo ABC contenido en este extinguidor (y otras unidades similares) puede producir daño y ser muy difícil de remover en la superficie del horno, incluyendo los que son auto-limpiantes. No use la función de auto-limpieza para eliminar el polvo ABC. Extinguidores con polvo químico BC son recomendados en las áreas de cocina.

**ATENCIÓN:** Procure no respirar este polvo. Los ingredientes del mismo no son tóxicos, pero pueden producir irritación en la piel. En caso de contacto con el mismo, lave la parte afectada con agua fría. Si la irritación persiste, consulte a su médico inmediatamente. El nombre del agente químico está impreso en la etiqueta.

Para más información sobre el combate contra incendio, consulte a su Departamento de Bomberos local, o a la Guardia Costera de los EEUU. Información adicional sobre extinguidores contra incendio puede recabarse en el boletín #10 de la Asociación Nacional de Protección contra Incendios (NFPA), denominado "Extinguidores contra Incendio Portátiles"

## Colocación de su Extinguidor

La aprobación de la Marina de los EEUU es válida sólo con el soporte especificado en la etiqueta ubicada en la parte posterior de su extinguidor. Los Modelos de KIDDE (5, 10, 110) están equipados con un soporte de plástico que es aceptado por La Marina de Los EEUU.

Guardia Costera favor de seguir las instrucciones y diagramas indicados abajo para montar el soporte que fue enviado con su extinguidor.

## Plastic Strap Bracket Instructions

Instrucciones del soporte con bandas plasticas en español


1



1. Fasten bracket to wall with appropriate fasteners (not included).

1. Fije el soporte en la pared con los sujetadores apropiados (no están incluidos).

2



2. Place extinguisher into bracket. Buckle straps together to lock in place.

2. Coloque el extinguidor en el soporte. Enganche las abrazaderas hasta unirse en sitio.

**IF YOUR EXTINGUISHER WAS SHIPPED WITH A PLASTIC BRACKET AND METAL STRAP** then mount your extinguisher as follows:

1. Fasten bracket to suitable surface using a screw in the upper bracket mounting hole.
2. Mount the metal strap provided with your extinguisher in the lower bracket mounting hole using another screw.
3. Place extinguisher into bracket and latch the strap to hold the extinguisher securely in place.

**SI SU EXTINGUIDOR FUE ENVIADO CON UNA BANDA DE METAL**, entonces monte su extinguidor de la siguiente manera:

1. Ponga el soporte en una superficie apropiada usando un tornillo de 1/4 de pulgada en diametro, ponga este en el agujero de arriba de la montura.
2. Monte la banda de metal que le ha sido proveida con su extinguidor en el agujero de abajo de la montura usando otro tornillo de 1/4 de pulgada en diametro.
3. Ponga el extinguidor en la montura y apriete la banda para que aguante el extinguidor seguro en su lugar.

**IF YOUR EXTINGUISHER WAS SHIPPED WITH A HOSE AND HOSE STRAP**, then slide the hose strap over the bottom of the cylinder, and secure the nozzle end of the hose to the hose strap before placing your extinguisher in service.

**SI SU EXTINGUIDOR FUE ENVIADO CON UNA MANGUERA Y UNA ABRAZADERA DE MANGUERA**, entonces, favor de sacar la abrazadera por la parte de abajo del cilindro, ajuste la manguera a la válvula del cuerpo y coloque la punta de la boquilla de la manguera a la abrazadera de la manguera antes de poner su extinguidor en servicio.

366224M

TEAR ALONG PERFORATIONS AND REMOVE

SERVICE/INSPECTION RECORD TAG  
(REQUIRED FOR UL LISTING)

MODEL NO.: \_\_\_\_\_  
SERIAL NO.: \_\_\_\_\_  
MFG. DATE: \_\_\_\_\_



REPLACE OR RECHARGE IMMEDIATELY AFTER USE

FOR RECHARGE INFORMATION  
CALL 1-800-880-6788

**IMPORTANT:** To ensure fire extinguisher will be ready when needed follow inspection and maintenance instructions in manual and familiarize yourself with operating instructions on the nameplate. Protect tag and extinguisher if exposed to weather.

DO NOT REMOVE OR ALTER THIS TAG

